

## Certificate of Analysis

<b>Lot No.:</b>	81412403	<b>Date Issued:</b>	20-Feb-2015
<b>Grade:</b>	AquaSorb CS, 20x40 mesh, 25 kg, JJ, 20 B/P	<b>Date Printed:</b>	11-Aug-2015

Parameter	Method	Spec. min	Spec. max	Value	Unit
Iodine Value	ASTM D4607	1000		<b>1157</b>	mg/g
Moisture Content, as packed	ASTM D2867		5.0	<b>2.8</b>	%
Total Ash Content	ASTM D2866		4.0	<b>2.8</b>	%
Ball Pan Hardness	ASTM D3802	97		<b>97</b>	%
Particle Size	ASTM D2862				
> 20			5.0	<b>1.8</b>	%
< 40			4.0	<b>2.1</b>	%

This document is valid and generated automatically from our Enterprise Quality Management system



This Activated Carbon is Tested and Certified by NSF International against NSF/ANSI Standard 42 for material requirements only.

**COMPONENT**



Certified to NSF/ANSI 61



Product is certified by the Water Quality Association to WQA/ASPE/ANSI S-802: Sustainable Activated Carbon for Drinking Water Treatment